

Vissolis 2.5m



Solar Specification In-Roof 2.5m System

Technical Data

Gross Area	2.52m ²
Aperture Area	2.33m ²
Absorber Area	2.82m ²
Collector Dimensions (L x W x D)	2.058m x 1.227m x 0.105m
Weight	49kg
Max Operating Pressure	10bar
Recommended Operating Pressure	6bar
Recommended Flow Rate	1L/min/m ²
Fluid Volume in Collector	1.8l
Rated Heat Output	1.81kW

Materials

Absorber	Aluminium
Coating	Highly Selected
Absorbance	95
Emissivity	5
Casing/Manifold	Timber
Glass	3.2mm tempered solar safety
Inlet Outlet Dimensions	3 ¼ flat seal threaded connection
Inclination	15°-75°
Stagnation	234°C
Insulation Material	50mm mineral wood plate
Heat Transfer Fluid	Propylene Glycol / Water mix
Efficiency Constants for G=8000W/m ²	$\eta_0 = 0.765$ $a_1 = 3.951$ $a_2 = 0.011$ (W/m ² K)

Test Results

Type	Test House	Test Results Number	Cert. Number	Result
Hall Impact	TUV Rheinland	EN 12975-1:2006	21215813_JL	✓
		EN 12975-2:2006		
Keymark	Fraunhofer Institute	EN 12975-1:2 2006	KTB Nr 2007-07-en	✓
		MCS 004 ISSUE 2.3		
MCS	Intertec	INT ST 21013		✓
NSAI	NSAI IRE	IBR 1997 2009	10/0353	✓

Slate Roof Flashing System

